

## पनवेल महानगरपालिका

ता. पनवेल, जि. रायगड, पिन नं. ४१० २०६



दूरध्वनी कार्यालय:-०२२-२७४५८०४०,४१,४२

फॅक्स :- ०२२-२७४५२२३३

ई-मेल :- panvelcorporation@gmail.com

वेबसाईट-www.panvelcorporation.com

जा.क्र. पमपा/पापुवि/६९५ / प्र.क्र.

12024

दि. १३/०६/२०२५

## जाहीर निविदा पत्रक

पनवेल महानगरपालिका क्षेत्रातील मार्केट यार्ड जलकुंभामध्ये १६० KVA क्षमतेचे डिझेल जनरेटर संच पुरविणे, बसविणे आणि कार्यान्वित करणे या कामाचे अंदाजपत्रक बनविण्याकरता खाली नमूद केलेल्या बाबीकरता खालील नमुन्यात दर मागविण्यात येत आहेत.

अ.क्र	कामाचे नाव	मुदत
१	पनवेल महानगरपालिका क्षेत्रातील मार्केट यार्ड जलकुंभामध्ये १६० KVA क्षमतेचे डिझेल जनरेटर संच पुरविणे, बसविणे आणि कार्यान्वित करणे.	92 /66 / २०२५ ते 93 /०६ / २०२५ (७ दिवस

Specification

Sr No	Description	Unit	QTY
1	Item No 1:- Supplying, erecting, testing and commissioning of diesel generating set with alternator of 160 kVA output continuous rating, 3 Phase,415 V, 50c/s 0.8 p. f. A.C supply, a totally enclosed air cooled / liquid cooled multi-cylinder diesel engi ne developing s uitable BHP at 1500 rpm with 10% overload for 1 hour in 12 hours, along with standard accessories, self-excited, self-regulated, scree n protected alternator with static excitations ystem running at 1500 RPM as per IS 4722-2001 with voltage regulation +/-5%, with performance class G2 and maximum fuel consumption 27.8 Ltr/hr@75% loa ding. Both the engine and alternator direct coupled on a common fabricated steel base frame and mounted on anti-vibrating pads with standard control panel comprising meters, switchgears, indicators connected with suitable wires/cables, the complete set enclosed in composite Acousticenclosure as fully assembled integral unit made of 16 SWG CRCA Sheet,s ound absorbing material to restrict sound level up to 75 dB at 1.0 m,provided with first filling of oil, diesel not less than 290 Ltr etc. on provided M20 Grade CC Foundation as per specification no. GEN-DG.	No.	1

वर नमूद सूचित दर्शविलेल्या बाबीचे पुरवठा करणारे पुरवठादार/दुकानदार/उत्पादक/विक्रेते/यांनी नमूद केलेल्या बाबीकरता असलेले दर स्वतःच्या लेटरहेडवर महापालिकेच्या कार्यालयात अथवा ई -मेल द्वारे panipurvathaoffice@gamil.com यावर दिनांक 9९ /०५ / २०२५ पर्यंत पाठवावे हि विनंती, सदर दर हे अंदाजपत्रक तयार करणेसाठी गृहीत धरण्यात येणार आहेत.

शहर अभियंता पनवेल महानगरपालिका

प्रत माहितीस्तव — १.प्रसिद्धीकरता. २.माहिती फलक करिता.